


# TOWN OF BRUTUS

9021 N Seneca St  
PO Box 720  
Weedsport, NY 13166



Ph: 315-834-9398  
Fax: 315-834-9381  
E-Mail: [townofbrutus@centralny.twcba.com](mailto:townofbrutus@centralny.twcba.com)

TDD 1-800-622-1220

The Town of Brutus is an Equal Opportunity Lender, Provider, Employer  
Complaints of discrimination should be sent to: **USDA, Director, Office of Civil Rights, Washington, D.C. 20250-9410**

Spring 2017

Dear Water District #8 Customer:

In order to ensure that water is safe to drink, NYS and the EPA (Environmental Protection Agency) have regulations in place which limit the amounts of certain contaminants found in water provided by public water systems. By law, water customers must be provided the opportunity to review the Annual Water Quality Report from the water supplier. The purpose of the report is to inform the public of any possible contaminants found in the drinking water supply, any possible associated health effects while increasing the awareness of drinking water and the need to protect our water sources.

Our water source is Owasco Lake. The Town of Brutus buys water from the Cayuga County Water and Sewer Authority (CCWSA) which obtains their water supply from the City of Auburn. An electronic version of the City of Auburn's 2016 Annual Water Quality Report is at:

[www.auburnny.gov/Public\\_Documents/AuburnNY\\_Uilities/Auburn-water-2016.pdf](http://www.auburnny.gov/Public_Documents/AuburnNY_Uilities/Auburn-water-2016.pdf).

Hard copies are available at the Town office, upon request.

Monthly testing and sampling is completed on a regular basis for WD # 8 by our water operator and those results, listed below, are an indicator that water in those particular systems meets all health standards, regulations, requirements and safety. If you have any questions regarding information on the report, contact the Town office at (315) 834-9398 or refer to [www.epa.gov/safewater](http://www.epa.gov/safewater) for further information.


Please note that the Water District # 8 system itself (piping, fittings) does not have any lead in it.

## COTTLE ROAD – WATER DISTRICT # 8 - WATER TESTING

CONTAMINANTS	VIOLATION	SAMPLE DATE	RESULT	UNITS	MCL	MCLG	SOURCES IN DRINKING WATER
DISINFECTION BY-PRODUCTS  TOTAL TRIHALOMETHANES (TTHMs)	NO	February, May, August & November of 2016	AVERAGE 71  RANGE 38.13-87.7	ug/l	80	N/A	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
DISINFECTION BY-PRODUCTS  HALOACETIC ACIDS	NO	February, May, August & November of 2016	AVERAGE 42  RANGE 32.5-51	ug/l	60	N/A	By-product of drinking water disinfection needed to kill harmful organisms.
INORGANICS  LEAD	NO	JUNE 2016	3 <sup>1</sup>  RANGE <1 - 5	ug/l	AL = 15	0	Corrosion of household plumbing systems; Erosion of natural deposits.

# TOWN OF BRUTUS

9021 N Seneca St  
PO Box 720  
Weedsport, NY 13166



Ph: 315-834-9398  
Fax: 315-834-9381  
E-Mail: townofbrutus@centralny.twcbc.com

TDD 1-800-622-1220

The Town of Brutus is an Equal Opportunity Lender, Provider, Employer

Complaints of discrimination should be sent to: **USDA, Director, Office of Civil Rights, Washington, D.C. 20250-9410**

INORGANICS LEAD	NO	OCT 2016	1.7 <sup>2</sup> RANGE <1 – 1.8	ug/l	AL= 15	0	Corrosion of household plumbing systems; Erosion of natural deposits.
INORGANICS COPPER	NO	JUNE 2016	0.31 <sup>3</sup> RANGE 0.026 – 0.44	mg/l	AL= 1.3	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
INORGANICS COPPER	NO	OCT 2016	0.27 <sup>4</sup> RANGE 0.047 – 0.28	mg/l	AL = 1.3	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.

1 – The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below that level. The 90th percentile is equal to or greater than 90% of the lead values detected in the water system. In this case, 10 samples were collected within the water system and the 90th percentile value was the average of the two highest values (3 ug/l). The action level for lead was not exceeded at any of the sites tested.

2 – The level presented represents the 90th percentile of the 10 samples collected. The action level for lead was not exceeded at any of the sites tested.

3 – The level presented represents the 90th percentile of the 10 samples collected. The action level for copper was not exceeded at any of the sites tested.

4 – The level presented represents the 90th percentile of the 10 samples collected. The action level for copper was not exceeded at any of the sites tested.

Sincerely,  
The Town of Brutus  
Water Department